


1. ALL PIPES SHALL BE CONSTRUCTED TO BE FLUSH WITH THE INSIDE WALLS.

2. CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL PIPING, INCLUDING PIPES BETWEEN VAULTS.





Ship hatch, frame, manhole ring and cover cast flush into lid. Lid elevation may be slightly above surrounding grade to provide positive drainage away from the device. TOP = 104.75 --- (SEE ELEV. NOTE) THICK CONC. TOP W/ HATCH AND MANHOLE ACCESS -2'-3" RISER AND LID SEAM 6 INCH 102.50 THICK WALLS 1 FLOW FLOW 3 INFLOW PIPE OUTFLOW PIPE 24" HDPE INVERT IN 100.00 24" HDPE INVERT OUT 2 (5) 99.80 SUMP 8' L x 6' W x 6' H 6 INCH 96.50 THICK WALLS PRECAST CONCRETE BOX SECTION "A"



LEGEND

- 1 EXPANDED ALUMINUM BASKET W/ 1/4" MESH LINING, 2'-0" H x 2'-0" L x 6'-0" W
- 2 1ST INTERNAL BAFFLE W/ 1" HOLES DRILLED AT 1-1/4" O.C., 3'-3" H.
- 3 2ND INTERNAL BAFFLE W/ 1" HOLES DRILLED AT 1 1/4" O.C., 5'-0" H.
- 4 SPILL PROTECTION RESERVOIR 4'-6"
 H. WITH A 1'-10" FRONT CUT.
- 5 3/4"COCONUT FIBER FILTER IN ALUMINUM FRAME 2'-2" LONG.
- 6 1/4"ALUMINUM PLATE, 9" H., 5'-6" WIDE.

,011, 6,994,783; 6,951,607; 6,939,461;

037,

THIS DRAWING IS COPYRIGHTED AND IS THE SOLE PROPERTY OF PRACTICAL BEST MANAGMENT, INC. IT IS PROVIDED FOR THE EXCLUSIVE USE OF THE PROFESSIONAL ENGINEER NAMED HEREON, DESIGNA IS BASED ON AND RELIES UPON DATA, PROVIDED BY THE ENGINEER NAMED HEREON. Technologies CrystalStream

1. TOTAL FLOW CAPACITY SHALL BE 13.5 CFS.
2. WATER QUALITY FLOW OF 2.26 CFS MUST BE TREATED WITH A HYDRAULIC LOADING RATE OF 22 GPM/SF OR LESS.
3. SPILL PROTECTION CAPACITY SHALL BE 783 GALLONS BEFORE OVERFLOW.
4. ANY CHANGES OR SUBSTITUTIONS MUST BE ANY CHANGES OR SUBS

 \subseteq

Drawi

8/19/2010

866 ..: CST-

. %

Device Mode Samp

DESIGN FIRM: CrystalStream Technologies

GA0-866-081910

CRYSTALSTREAM "CRYSTALCLEAN" WATER QUALITY VAULT MODEL "866"